



BEST AVAILABLE CONTROL TECHNOLOGY (BACT) GUIDELINE 1.3.2

| | |
|----------------------------|---|
| Equipment Category: | External Floating Roof Tanks in Oil and Gas Service |
| Revision: | 1.1 |
| Date: | June 14, 2017 |

The installation of a dome shall be required for all BACT floating roof tanks. See BACT Guideline 1.3.3.