



Santa Barbara County  
Air Pollution Control District

**SBCAPCD Default Boiler/Process Heater/Large Water Heater/  
Steam Generator Emission Factors (Rev. 2.0, 8/28/2018)**

Rated Heat Input (Btu/hr)	Emission Factor (lb/MMBtu)						
<b>75,000 – 400,000</b>	<b>NO<sub>x</sub></b>	<b>ROC</b>	<b>CO</b>	<b>SO<sub>x</sub></b>	<b>PM</b>	<b>PM<sub>10</sub></b>	<b>PM<sub>2.5</sub></b>
<i>Uncontrolled<sup>a</sup></i>	0.0920	0.0054	0.0393	0.169 * S / HHV <sup>b</sup>	0.0075	0.0075	0.0075
<i>Rule 360</i>	0.0670	0.0054	0.0393	0.169 * S / HHV <sup>b</sup>	0.0075	0.0075	0.0075
<i>BACT</i>	0.0244	0.0054	0.0371	0.0137	0.0075	0.0075	0.0075
<b>400,001 – 2,000,000</b>	<b>NO<sub>x</sub></b>	<b>ROC</b>	<b>CO</b>	<b>SO<sub>x</sub></b>	<b>PM</b>	<b>PM<sub>10</sub></b>	<b>PM<sub>2.5</sub></b>
<i>Uncontrolled<sup>a</sup></i>	0.0980	0.0054	0.0820	0.169 * S / HHV <sup>b</sup>	0.0075	0.0075	0.0075
<i>Rule 360</i>	0.0365	0.0054	0.2965	0.169 * S / HHV <sup>b</sup>	0.0075	0.0075	0.0075
<i>BACT</i>	0.0146	0.0054	0.0741	0.0137	0.0075	0.0075	0.0075

<b>2,000,001 – 4,999,999</b>	<b>NO<sub>x</sub></b>	<b>ROC</b>	<b>CO</b>	<b>SO<sub>x</sub></b>	<b>PM</b>	<b>PM<sub>10</sub></b>	<b>PM<sub>2.5</sub></b>
<i>Uncontrolled<sup>a</sup></i>	0.0980	0.0054	0.0820	0.169 * S / HHV <sup>b</sup>	0.0075	0.0075	0.0075
<i>Rule 361</i>	0.0365	0.0054	0.2965	0.169 * S / HHV <sup>b</sup>	0.0075	0.0075	0.0075
<i>BACT</i>	0.0110	0.0054	0.0741	0.0137	0.0075	0.0075	0.0075

<b>5,000,000 – 19,999,999</b>	<b>NO<sub>x</sub></b>	<b>ROC</b>	<b>CO</b>	<b>SO<sub>x</sub></b>	<b>PM</b>	<b>PM<sub>10</sub></b>	<b>PM<sub>2.5</sub></b>
<i>Uncontrolled<sup>a</sup></i>	0.0980	0.0054	0.0820	0.169 * S / HHV <sup>b</sup>	0.0075	0.0075	0.0075
<i>Rule 342</i>	0.0365	0.0054	0.2965	0.169 * S / HHV <sup>b</sup>	0.0075	0.0075	0.0075
<i>BACT</i>	0.0110	0.0054	0.0741	0.0137	0.0075	0.0075	0.0075
<b>20,000,000 – 25,999,999</b>	<b>NO<sub>x</sub></b>	<b>ROC</b>	<b>CO</b>	<b>SO<sub>x</sub></b>	<b>PM</b>	<b>PM<sub>10</sub></b>	<b>PM<sub>2.5</sub></b>
<i>Uncontrolled<sup>a</sup></i>	0.0980	0.0054	0.0820	0.169 * S / HHV <sup>b</sup>	0.0075	0.0075	0.0075
<i>Rule 342</i>	0.0365	0.0054	0.2965	0.169 * S / HHV <sup>b</sup>	0.0075	0.0075	0.0075
<i>BACT</i>	0.0085	0.0054	0.0741	0.0137	0.0075	0.0075	0.0075
<b>26,000,000 and Greater</b>	<b>NO<sub>x</sub></b>	<b>ROC</b>	<b>CO</b>	<b>SO<sub>x</sub></b>	<b>PM</b>	<b>PM<sub>10</sub></b>	<b>PM<sub>2.5</sub></b>
<i>Uncontrolled<sup>a</sup></i>	0.0980	0.0054	0.0820	0.169 * S / HHV <sup>b</sup>	0.0075	0.0075	0.0075
<i>Rule 342</i>	0.0365	0.0054	0.2965	0.169 * S / HHV <sup>b</sup>	0.0075	0.0075	0.0075
<i>BACT</i>	0.0061	0.0054	0.0741	0.0137	0.0075	0.0075	0.0075

**BACT Oilfield Steam Generators**

	<b>NO<sub>x</sub></b>	<b>ROC</b>	<b>CO</b>	<b>SO<sub>x</sub></b>	<b>PM</b>	<b>PM<sub>10</sub></b>	<b>PM<sub>2.5</sub></b>
<i>5,000,000 – 19,999,999</i>	0.0110	0.0054	0.0371	0.0137	0.0075	0.0075	0.0075
<i>20,000,000 - 49,999,999</i>	0.0085	0.0030	0.0185	0.0137	0.0075	0.0075	0.0075
<i>50,000,000 – 84,999,999</i>	0.0085	0.0036	0.0185	0.0137	0.0075	0.0075	0.0075
<i>85,000,000 and Greater</i>	0.0085	0.0017	0.0185	0.0137	0.0075	0.0075	0.0075

Notes:

- a. To determine the uncontrolled NO<sub>x</sub> emission factor for a unit fired on propane fuel, multiply the uncontrolled NO<sub>x</sub> emission factor by 1.5. This is the approximate ratio of propane NO<sub>x</sub> emissions to natural gas NO<sub>x</sub> emissions per AP-42, Table 1.5-1, Emission Factors for LPG Combustion (10/96).
- b. S means the sulfur content of the fuel (ppmv) and HHV means the higher heating value of the fuel (Btu/scf).
- c. All the emission factors are based the combustion of PUC quality natural gas. The PUC quality natural gas is assumed to have a molar volume of 379.7 dscf/lb-mol at standard temperature and pressure (1 atm and 60° F) and F<sub>d</sub> factor of 8,608 dscf/MMBtu.